

CERTIFICATE OF COMPLIANCE

Certificate Number EX26809
Report Reference EX26809-20161028
Date 2021-June-25

Issued to: TECNOTUBI S.p.A.
Via Mazzini 240/242
AlfianelloBS 25020 IT

This is to certify that METALLIC SPRINKLER PIPE
representative samples of See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852, Metallic Sprinkler Pipe for Fire Protection Service
ULC/ORD C199S, Light Wall Steel Pipes for Sprinkler Systems for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number EX26809
Report Reference EX26809-20161028
Date 2021-June-25

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Models:
Metallic Sprinkler Pipe

Schedule 10, 30, 40, and 80 steel sprinkler pipe for wet, dry, preaction and deluge type sprinkler systems with threaded or unthreaded ends intended to be joined by welding or Listed Rubber Gasketed Fittings when installed in accordance with the fitting manufacturer's specifications.

Schedule 10 steel sprinkler pipe, (black, painted or hot dip galvanized), 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 6, and 8 inch sizes

Schedule 30 steel sprinkler pipe, (black, painted or hot dip galvanized), 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, and 8 inch sizes

Schedule 40 steel sprinkler pipe, (black, painted or hot dip galvanized), 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 6, and 8 inch sizes

Schedule 80 steel sprinkler pipe, (black, painted or hot dip galvanized), 2, 2-1/2, 3, 3-1/2, and 4 inch sizes



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>